


Environmental Engineering

- Raw water Engi.
- Waste water Engi.
- Air & Noise Pollution



Water Demand.

- Any sample of water which is been utilized from the natural source & is not being subjected to artificial treatment is termed as raw water.
- Before designing the raw water scheme, following quantities are being computed -
 - i) Total amount of water req. in the community in 1 year
(Note- Annual draft.)
 - ii) Total amount of water req. in the community in 1 day
(Annual average daily draft)
 - iii) Total amount of water req. in the community in 1 day by each individual (Annual average per capita daily draft)

The total demand of the water consist of the following -

i) Domestic water demand :- It is the amount of water req. to satisfy the domestic needs by like drinking, cooking, washing, bathing etc.

For a city having full flushing system - it is in the range of 135-225 lit/c/d. Normally taken to be 200 lit /c/d.

ii) Industrial water demand :- It is the amount of water req. to satisfy the industrial needs.

Depending upon the extent of industrialisation, it is in the range of 50-450 lit/c/d.

iii) Institutional water demand :- It is the amount of water req. to satisfy the needs of diff. institutes in the community like - schools, hospitals, railway station, airport etc.

It is in the range of 20-50 lit/c/d.

iv) Water for Public use :- It is the amount of water req. for public utility purposes like washing of roads, gardening etc.

It is taken to be 5-6% of total demand of water. (10-20 lit/c/d)

v) Fire demand :- It is the amount of water req. in case fire breaks out. It is taken to be 1 lit/c/d & can also be found empirically as follows -

$$FD = 100 \sqrt{P} (\text{kl}) \quad \text{or} \quad FD = 4637 \sqrt{P} (1-0.01\sqrt{P}) (\text{l/min})$$

↑
GOI Manual

↑
National board of fire under writers method.

P → Population (in thousand)

i) Losses & theft :- It is the amount of water which is being wasted out due to leakages & theft in raw water scheme. It may extend upto 10-15% of total demand of water.

Unless given fluctuation in the demand of ^{wa}ter are taken as follows -

. Max. daily demand = $1.8 \times$ Annual avg. daily demand.

$$\text{Max. hourly demand} \rightarrow \text{hourly variation factor} = (1.5) \text{ Avg. hourly demand of max. day} \quad (2)$$

$$= \frac{1.5 \times \text{Max. daily demand}}{24}$$

$$= 1.5 \times \frac{1.8 \text{ Annual avg. hourly demand}}{24}$$

$$\text{Max. hourly demand} = 2.7 \times \text{Annual avg. hourly demand} \times \sqrt{\frac{V}{365 \times 24}}$$

Note:- % ratio of Max. demand to the avg. demand for any duration, can be computed using goodrich eq. as follows-

$$P = \frac{\text{Max. demand}}{\text{Avg. demand}} = 180 t^{-0.1}$$

$t = \text{time (days)}$

$t \geq 1 \text{ day}$

Demand - fluctuation

Hourly - 2.7

Daily - 1.8

Weekly - 1.48

Monthly - 1.28

Yearly - 1

fluctuation in hourly demand is observed to be max. & it tapers off from hourly to yearly demand due to increase in sample size.

fluctuation in hourly demand is termed as peak factor which also depends upon the population as follows-

Population	Peak factor
< 50000	3
50000 - 200000	2.5
> 200000	2


Coincident demand: It is defined as the aggregate of max daily demand & fire demand.

$$Q_{MH}$$

$$Q_{MH} + Q_{FD} \rightarrow Q_{FD} = Q_{MH}$$

$$Q_{MD} + Q_{FD} \rightarrow Q_{CD} = Q_{MD} \text{ Max}$$

- design life & design discharge of different component scheme are as follows -



Q- A city with the population of 1.8 Lakh has per capita water demand of 300 lit/day. It is to be provided with the water supply scheme. Report the imp. type of demand of this water supply scheme & also indicate the design capacity of different components of this water supply scheme.

$$\text{Annual avg. daily demand} = 300 \times 1.8 \times 10^5 \times 10^{-6}$$

$$q = 54 \text{ MLD}$$

$$\text{Max. daily demand } Q_{MD} = 1.8 \times q = 97.2 \text{ MLD}$$

$$\text{Max. hourly demand } Q_{MH} = 2.7 \times \frac{q}{24} = 6.075 \text{ MLH}$$

or

$$145.8 \text{ MLD}$$

$$\begin{aligned} \text{Fire demand } Q_{FD} &= 4637 \sqrt{P} (1 - 0.01 \sqrt{P}) \\ &= 4637 \sqrt{180} (1 - 0.01 \sqrt{180}) \\ &= 53865.28 \text{ l/min} \\ &= 53865.28 \times 10^{-6} \times 60 \times 24 \\ &= 77.56 \text{ MLD} \end{aligned}$$